

Type of Facility:	Health Care Facility		
Facility Group Name:	Sun Country Health Authority		
Facility Name:	Carnduff Sunset Haven		
Location:	415 Spencer Street, Carnduff, SK		
Date of Submission:	21-Dec-18		
Primary Contact Name:	Marlon Milbrandt	Secondary Contact Name:	John Megenbir
Primary Contact Title:	Director - Building Services Rural	Secondary Contact Title:	Building Services Manager
Primary Contact Email Address:	Marlon.Milbrandt@saskhealthauthority.ca	Secondary Contact Email Address:	John.Megenbir@saskhealthauthority.ca
Primary Contact Telephone:	(306) 786-0416	Secondary Contact Telephone:	(306) 842-8377
Primary Contact Preferred Method:	Email	Secondary Contact Preferred Method:	Email

1. Type of Asbestos Containing Material [ACM]	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Drywall Mud Compound	The asbestos-containing Drywall Mud Compound was identified in the following areas of the facility: Main Entrance. Consider all Drywall Mud Compound to be asbestos-containing until further testing proves otherwise.	The Drywall Mud Compound contains 2% Chrysotile asbestos and is considered a non-friable asbestos material. Drywall Mud Compound is located at drywall seams/joints and nail/screw holes throughout the facility.	High	A non-friable product is one that cannot be crumbled or reduced to powder or smaller fragments by hand pressure.
Gasket Material	The asbestos-containing Gasket Material was identified in the following areas of the facility: Maintenance Shop.	The Gasket Material contains 30-40% Chrysotile asbestos and is considered a friable asbestos material. The Gasket Material is located on the duct in the maintenance shop.	Low	A friable product is one that can be crumbled or reduced to powder or smaller fragments by hand pressure.
Heat Shield Material	The asbestos-containing Heat Shield Materials were identified within the following areas within the facility: East House Keeping and North House Keeping.	The Heat Shield Material contain 80% Chrysotile asbestos are considered a friable asbestos material. The Heat Shield is located directly above the light bulbs within the light fixture to prevent overheating of building materials above.	Low	A friable product is one that can be crumbled or reduced to powder or smaller fragments by hand pressure. Ensure the globe of the light fixture is in place to enclose/conceal the Heat Deflector Shield.
Sheet Flooring	The asbestos-containing Sheet Flooring was identified within the following areas of the facility: Main Floor Resident Rooms 1-4, 6-8, and 15. North House Keeping, Med Room, Clean Utility and Recessed Room.	The Sheet flooring contains 30% Chrysotile asbestos and is considered a friable asbestos material. The sheet flooring was found in a variety of colours and patterns throughout the facility.	High	The asbestos is present within the felt backing beneath the surface of the flooring. A friable product is one that can be crumbled or reduced to powder or smaller fragments by hand pressure.