

Type of Facility:	Health Care Facility		
Facility Group Name:	Sun Country Health Authority		
Facility Name:	Wawota Memorial Health Centre		
Location:	Choo Foo Crescent		
Date of Submission:	14-Dec-18		
Primary Contact Name:	Marlon Milbrandt	Secondary Contact Name:	Barry Brumfield
Primary Contact Title:	Director - Building Services Rural	Secondary Contact Title:	Building Services Manager
Primary Contact Email Address:	Marlon.Milbrandt@saskhealthauthority.ca	Secondary Contact Email Address:	Barry.Brumfield@saskhealthauthority.ca
Primary Contact Telephone:	(306) 786-0416	Secondary Contact Telephone:	(306) 842-8316
Primary Contact Preferred Method:	Email	Secondary Contact Preferred Method:	Email

1. Type of Asbestos Containing Material [ACM]	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Transite Pipe	The asbestos-containing Transite Pipe was identified within the ceiling space of the following areas of the facility: Staff Room, Staff Washroom, and the Main Corridor.	The Transite Pipe contains 30% Chrysotile asbestos and is considered a non-friable asbestos material.	Low	A non-friable product is one that cannot be crumbled or reduced to powder or smaller fragments by hand pressure.