

Type of Facility:	Health Care Facility		
Facility Group Name:	Sun Country Health Authority		
Facility Name:	Carlyle Moose Mountain Lodge		
Location:	801 Souris Avenue, Carlyle, SK		
Date of Submission:	13-Dec-19		
Primary Contact Name:	John Megenbir	Secondary Contact Name:	Marlon Milbrandt
Primary Contact Title:	Maintenance Manager	Secondary Contact Title:	Director - Building Services Rural
Primary Contact Email Address:	John.Megenbir@schr.sk.ca	Secondary Contact Email Address:	Marlon.Milbrandt@saskhealthauthority.ca
Primary Contact Telephone:	306-842-8377	Secondary Contact Telephone:	(306) 786-0416
Primary Contact Preferred Method:	Email	Secondary Contact Preferred Method:	Email

1. Type of Asbestos Containing Material [ACM]	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Drywall Mud Compound	The asbestos-containing Drywall Mud Compound was identified in the following areas of the facility: Compilation samples were taken from Main Floor Corridor. Consider all Drywall Mud Compound to be asbestos-containing until further testing proves otherwise.	The Drywall Mud Compound contains 1-5% Chrysotile asbestos and is considered a non-friable asbestos material. Drywall Mud Compound is located at drywall seams/joints and nail/screw holes throughout the facility.	High	A non-friable product is one that cannot be crumbled or reduced to powder or smaller fragments by hand pressure.
Sheet Flooring	The asbestos-containing Sheet Flooring was identified within the following areas of the facility: Resident / Storage Rooms 1-15, 17, 20-25, 27-35 and the Storage Room adjacent Room #25.	The Sheet flooring contains 40% Chrysotile asbestos and is considered a friable asbestos material. The sheet flooring was found in a variety of colours and patterns throughout the facility.	High	The asbestos is present within the felt backing beneath the surface of the flooring. A friable product is one that can be crumbled or reduced to powder or smaller fragments by hand pressure.
Vermiculite	The asbestos-containing Vermiculite was identified within the following areas of the facility: Attic of South, East, and North Wings.	The Vermiculite insulation contains Actinolite/Tremolite asbestos and is considered a friable asbestos material.	Low	A friable product is one that can be crumbled or reduced to powder or smaller fragments by hand pressure. Vermiculite determined to contain any asbestos is deemed asbestos containing material.