

Asbestos Registry Submission Form

Facility Group:	Healthcare		
Facility Group Name:	Sun Country Regional Health Authority		
Facility Name:	Wawota Memorial Health Centre		
Street Address:	Choo Foo Crescent		
City:	Wawota, SK		
Primary Contact Name:	Sam Baison	Secondary Contact Name:	John Megenbir
Primary Contact Title:	Director - Physical Plant	Secondary Contact Title:	Maintenance Manager
Primary Contact Email Address:	Samuel.Baison@schr.sk.ca	Secondary Contact Email Address:	John.Megenbir@schr.sk.ca
Primary Contact Telephone:	306-842-8304	Secondary Contact Telephone:	306-842-8377
Primary Contact Preferred Method:	Email	Secondary Contact Preferred Method:	Email
Date Submitted:	June 30, 2016		

1. Type of Asbestos-Containing Material (ACM) (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (Optional)
Transite Pipe	Asbestos transite pipe was identified in the ceiling space of the Staff Room, the Staff Washroom and the Main Corridor. All transite pipe located within the facility shall be considered asbestos-containing until the material is determined to be asbestos free.	The transite pipe contains 30% Chrysotile Asbestos and is considered a non-friable asbestos material.	Low. Contained within the ceiling space. Accessible only by maintenance personnel.	A non-friable product is one that cannot be crumbled or reduced to powder or smaller fragments by hand pressure.