

# Asbestos Registry Submission Form

<b>Facility Group:</b>	Healthcare	<b>Secondary Contact Name:</b>	John Megenbir
<b>Facility Group Name:</b>	Sun Country Regional Health Authority	<b>Secondary Contact Title:</b>	Maintenance Manager
<b>Facility Name:</b>	Weyburn Special Care Home	<b>Secondary Contact Email Address:</b>	John.Megenbir@schr.sk.ca
<b>Street Address:</b>	704 - 5th Street NE	<b>Secondary Contact Telephone:</b>	306-842-8377
<b>City:</b>	Weyburn, SK	<b>Secondary Contact Preferred Method:</b>	Email
<b>Primary Contact Name:</b>	Sam Baison		
<b>Primary Contact Title:</b>	Director - Physical Plant		
<b>Primary Contact Email Address:</b>	Samuel.Baison@schr.sk.ca		
<b>Primary Contact Telephone:</b>	306-842-8304		
<b>Primary Contact Preferred Method:</b>	Email		
<b>Date Submitted:</b>	June 30, 2016		

1. Type of Asbestos-Containing Material (ACM) (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (Optional)
Sheet Vinyl Floor	Asbestos-containing sheet vinyl floor was identified throughout much of the Main Floor of the facility.	The sheet vinyl floor contains 30% Chrysotile Asbestos and is considered a friable asbestos material. The flooring is identifiable by the stone pattern.	Low. The asbestos is present within the felt backing beneath the surface of the flooring.	Ensure the facing surface of the sheet flooring is maintained in good repair.
Heat Deflector Shield	Asbestos heat deflector shield material was identified within the Basement in the following areas: Corridor C01S, Storage Room 06S and Washroom 07S. All heat shield material shall be considered asbestos-containing until the material is determined to be asbestos free.	The Heater Deflector Shield Material contains 60% Chrysotile Asbestos and is considered a friable asbestos material. The Heat Deflector Shields are located in the old Incandescent light fixtures in the rooms identified.	Low. Access to this area is restricted to Maintenance personnel.	A friable product is one that is easily crumbled by hand pressure.
Transite Pipe	Asbestos transite pipe was identified within the South Crawlspace. All Transite Pipe (cement pipe) located within the facility shall be considered asbestos-containing until the material is determined to be asbestos free.	The Transite Cement Pipe contains 25%/5% Chrysotile & Crocidolite Asbestos respectively and is considered a non-friable asbestos material.	Low	A non-friable product is one that cannot be crumbled or reduced to powder or smaller fragments by hand pressure.